

NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals
Authorized Registered Formulation

Reason for Revision: PA223424, MUL revision, add listing note

Customer Name: ENVIRO TECH CHEMICAL SERVICE INC

Facility Location: MODESTO, CA

Customer Number: 1C110

Facility At: MODESTO, CA

Facility Number: 1C111

Trade Name Level Functions: Membrane Cleaner, Reverse Osmosis Antiscalant

Trade Name(s)	MUL(mg/L)
BioSide™ HS 15%	30
BioSide™ HS 5%	90
PERASAN™	30
PERASAN™ 'A'	90

Listing Notes

This product is designed to be used upstream of a carbon absorption system. Use of this product shall be followed by chlorination to remove trace levels of hydrogen peroxide.

Section/Category: MWSP, SECTION 8 - MISC. WATER SUPPLY PRODUCTS

Chemical Name: Miscellaneous Water Supply Products

Physical State: Liquid

Auditor Notes

Please note the product trade name on the PSF.

Bracketing

This product covers the testing and evaluation of DA04419.

Sample Notes

Please collect a sample of PERASAN (formulation 1).

NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals
Authorized Registered Formulation

Customer Name: ENVIRO TECH CHEMICAL SERVICE INC

Facility Location: MODESTO, CA

Customer Number: 1C110

Facility At: MODESTO, CA

Facility Number: 1C111

Trade Name Level Functions: Membrane Cleaner

Trade Name(s)	MUL(mg/L)
BioSide™ HS 15%	N/A
BioSide™ HS 5%	N/A
PERASAN™	N/A
PERASAN™ 'A'	N/A

Listing Notes

These products are designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.

The pH of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.

Drain and flush system until the hydrogen peroxide and peracetic acid concentrations fall below 1 ppm.

Section/Category: MWSP, SECTION 8 - MISC. WATER SUPPLY PRODUCTS**Chemical Name:** Miscellaneous Water Supply Products**Physical State:** Liquid

Bracketing

Testing and evaluation of this product is covered by the testing of DA02920.

Sample Notes

Please do not collect a sample.
